


CORP "A"


CORP "B"

LEGENDA:

- Corp de iluminat tip aplica 1x60W  
Lighting fixture bracket type 1x60W
- Corp de iluminat fluorescent 2x36W montat aparent  
Fluorescent lighting fixture 2x36W apparent mounting
- Corp de iluminat fluorescent 1x36W montat aparent  
Fluorescent lighting fixture 1x36W apparent mounting
- Corp de iluminat fluorescent 2x18W montat aparent, constructie etansa  
Fluorescent lighting fixture 2x18W apparent mounting, water proof construction
- Corp de iluminat fluorescent 1x18W montat aparent, constructie etansa  
Fluorescent lighting fixture 1x18W apparent mounting, water proof construction
- Corp de iluminat fluorescent 1x36W montat aparent, constructie etansa  
Fluorescent lighting fixture 1x36W apparent mounting, water proof construction
- Corp de iluminat fluorescent 2x8W montat aparent pentru evacuare  
Fluorescent lighting fixture 2x8W apparent mounting to evacuate
- Corp de iluminat fluorescent 2x8W montat aparent pentru hidranti  
Fluorescent lighting fixture 2x8W apparent mounting for hydrants
- Interrupator simplu 250V/10A  
One way switch 250V/10A
- Interrupator dublu 250V/10A  
One way two poles switch 250V/10A
- Interrupator cap scara 250V/10A  
One way stair switch 250V/10A
- Interrupator cruce 250V/10A  
One way cross switch 250V/10A
- Priza 16A/230V cu contact de protectie  
Socket 16A/230V with earth contact
- Priza 16A/230V cu contact de protectie, constructie etansa  
Socket 16A/230V with earth contact water proof construction
- Priza telefon  
Phone socket
- Priza calculator  
Calculator socket
- Priza calculator  
Calculator socket
- Traseu circuite montat in tub de protectie  
Circuit copre mounted in protection tube
- Traseu circuite multiple  
Multiple circuit
- Traseu calculator  
Calculator copre
- Traseu difuzoare  
Speakers copre
- Apelator telefonic/Phone
- Centrala avertizare incendiu/Fire station
- Buton incendiu/Fire button
- Detector optic de fum/Optic smoke detector
- Sirena incendiu/Fire siren
- Difuzor / Speaker
- Amplificator



NOTA: ALL MEASUREMENTS SHOULD BE MADE ON SITE/TOATE MASURATORILOR SA SE FACA LA FATA LOCULUI

VERIFICATOR: ILL.P.AT.	NUME NAME	SERINATURA SIGNATURE	DEPRITA REQUIREMENT	REFERAT / EXPERTIZA NR. / DATA REPORT / TECHNICAL EXPERTISE / DATE
VERIFICATOR: ILL.P.AT.				
PROJECT DESIGN COORDINATOR: COORDINATOR PROJECT: <b>THE LOUIS BERGER GROUP, INC</b>				
BUCHAREST SCHOOLS INFRASTRUCTURE REHABILITATION / REABILITAREA INFRASTRUCTURII EDUCATIONALE IN MUNICIPIUL BUCURESTI				
DESIGNER/PROJECTOR:				
				
SECRETARY/REVIEWER: MUNICIPALITY OF BUCHAREST PRIMARIA MUNICIPIULUI BUCURESTI				
SCHOOL NAME/ NUME SCOLA: General School no. 36 / Scoala Generala nr. 36				
ELECTRICAL INSTALATION / INSTALATI ELECTRICE				
BUILDING "A" / CORP "A"				
2 ND FLOOR PLAN PLAN ETAJ 2				
PLAN ET AJ 2				
DATE/ DATA 04/2006	SCALE/ SCALA 1 : 50	EXEMPLAR NR. Detailed Design Project Intend:	PROJ. No./Nr-PROJECT 063/S4	DRWG. No./Nr. PLANSA A - EL - 004