

Obiectivul de investiții: **Reabilitare rețele termice primare Banu Manta – Calea Plevnei – Giulești – Pod Grand – CET Griro**

Nr crt	Indicator	U.M.	Situatia existenta	Situatia proiectata
	A. Varianta statica			
1	Valoarea totala, din care C+M	RON RON		13.180.549,52 11.485.483,84
2	Capacitati Debit transportat Lungime tronson	Gcal/h m	119,99 iarna 15,93 vara 905	119,99 iarna 15,93 vara 1063
3	Durata de realizare a lucrarilor	luni		12
4	Venituri anuale din activitatea de transport si distributie	RON	102.906.702	102.906.702
5	Costuri anuale totale	RON	101.481.269	101.068.013
6	Volum anual de energie termica	Gcal/an	598..922	598.922
7	Costul energiei termice	RON/Gcal	169,44	168,75
8	Profit net anual	RON	1.197.364	1.544.499
9	Rata profitului	%	1,18	1.53
10	Termenul de recuperare a investitiei	ani		31,91
	B. Varianta dinamica			
1	Rata de actualizare	%		8
2	VNA (Venitul net actualizat) pe durata eficienta de functionare	RON/30 ani		15.957.543
3	Raportul venituri totale actualizate/Cheltuieli totale actualizate			1.02



A handwritten signature, likely of the official responsible for the document, is located in the bottom right corner.